

Fire Application #264655 - Lakeview Operations

[illegible]



CITY OF KIRKLAND



Fire Application #264655 - Lakeview Operations

Project Contact

Company Name: Patriot Fire Protection, Inc.

Name: John Dacca

Email: johnd@patriotfire.com

Address: 2707 70th Ave E

Phone #: (253) 405-4469

Tacoma WA 98424

Project Type

Nonresidential

Activity Type

Alteration

Scope of Work

Fire Sprinkler Systems

Project Name: Lakeview Operations

Description of Work: Install new pipe on levels 1 and 2 for new tenant improvements.

Project Details

System Information

This is a modification or addition to an existing system

Fire System Type

NFPA 13

Alterations

There are alterations to devices or systems.

Quick Response or Recalled Head Change Out

The K-Factor and spacing match existing.

Quick Response or Recalled Head Relocation

No heads are being relocated.

Change of Use

This is not a change of use.

Hydraulic Calculations

There is a change to the hydraulic calculations.

Hazard Classification

The space is classified as Light/Ordinary Hazard.

Mains and Cross Mains

Mains or cross mains are being relocated.

Heads - Excluding Quick Response and Recalled

101 - 1000 total heads

Fire System Counts

Number of Heads Added	199
Number of Quick Response Heads	18
Number of Total Heads	217